

CATERING VEHICLE/TRAILER CHECK

Certificate Reference: 701

DETAILS OF THE INSTALLATION ADDRESS	DETAILS OF THE CLIENT ADDRESS
Installation Address: Jordan Boon 13 Penhale road, Fratton Postcode: PO15EE	Client Address: Postcode:

VEHICLE DETAILS				
Type: bbq	Reg/Chassis No: bbq	Is a fire extinguisher available	YES	
Is the cylinder housing adequate		YES	Is LPG safety information displayed	YES
Is a fire blanket available		YES	Is there a safety ticket displayed	YES

APPLIANCE DETAILS							
	Appliance Type	Make	Model	Serial No	Appliance Secured	Isolation Value Fitted	Flue Type
1	bbq	nk	nk	nk	na	Yes	FL
2							
3							
4							
5							

INSPECTION DETAILS								
	Operating Pressure in mbar or heat input in kW	Safety Devices(s) Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue and Termination Satisfactory	Flue Performance Test	Appliance Serviced	Spillage Check	Appliance Safe To Use
1	37	Yes	N/A	N/A	N/A	No	N/A	Yes
2								
3								
4								
5								

Emergency Control Valve accessible	YES	Connection hose to installation adequate	YES
Gas Tightness Test satisfactory	YES	Regulator working pressure:	37 mbar
Visual Inspection satisfactory	YES	Regulator lock up pressure:	51 mbar

DETAILS OF WORK CARRIED OUT

DETAILS OF REMEDIAL WORK REQUIRED

DETAILS OF THE CONTRACTOR			
Trading Title: Alan Forrest 2 Otterburn Grove Blyth Postcode: NE24 4QP	Gas Safe Number: 125570		
	Gas ID Number: 4034043		
	Telephone Number: 0800289654		
Report Issued By: Name: Alan Forrest	Signature: 	Date: 11/07/2017	
Report Received By: Name: Jordan Boon	Signature: 	Date: 11/07/2017	

THE NEXT GAS SAFETY CHECK MUST BE COMPLETED WITHIN THE NEXT 12 MONTHS OR PREFERABLY SOONER.